



400 Amp Load Center

1. All wiring must meet the current National Electric Code.
2. Any conduit or wire out of disconnects (services) must have State rough-in inspection
3. All conduit under driveway shall be Sch 80
4. Only one ground wire per clamp
5. Ground Rod Clamps must be direct burial rated.